

**BEFORE THE 2008 JUDICIAL COUNCIL OF GUAM
RESOLUTION NO. JC 08-009**

**RELATIVE TO APPROVAL OF EXPENDITURE OF EMERGENCY FUNDS FROM
JUDICIAL BUILDING FUND**

WHEREAS, the Judiciary of Guam Facilities and Maintenance Manager reported that in the electrical room at the old Superior Court Building (OSC)), it was necessary to construct a concrete shelter that will house a new electrical switch board at the OSC building, because the existing electrical room also houses the mechanical equipment for the A/C system in the OSC building. The moisture created by the mechanical equipment is causing the electrical switch board to rust/corrode causing some electrical problems such as low voltages to electrical equipment and devices. If this is allowed to continue the building will soon be encountering electrical outages. Due to moisture the electrical switch board is severely rusted and must be replaced immediately. The amount requested is Requested Amount: \$75,000.00; and

NOW THEREFORE BE IT RESOLVED, that the sum of approximately \$75,000.00 be approved to be spent from the Judicial Building Fund to repair the problem outlined above.

DULY ADOPTED this 17th day of April, 2008 at a duly noticed meeting of the Judicial Council of Guam.



ROBERT J. TORRES, Chairman

Date: 10-6-08

ATTEST:



JOLEEN F. RESPICIO, Secretary

Date: 10/7/08